

## Duct Sealant

Provide and apply duct sealant as manufactured by Ward Industries as shown on plans. Sealant shall be applied according to SMACNA Duct Construction Standard Section 1.6 and 1.7. Sealer shall be UL Classified for surface burning characteristics. Specifier to select high velocity solvent-based sealant: Ward SSB; water-based reinforced sealant: Ward SWB-R; water-based non-reinforced sealant: Ward SWB-N.