

Insulation Adhesive

Provide and apply adhesive as manufactured by Ward Industries on all lined metal duct. Adhesive shall be applied according to SMACNA Duct Construction Standard Section 2.6. Each layer of duct liner shall be attached with 90% coverage of adhesive at the liner contact surface area. Adhesive shall be UL Classified for surface burning characteristics. Specifier to select roller application adhesive: Ward ART; spray application adhesive: Ward AST.