



Performance Testing

Test Standard	FastWrap XL	PlenumWrap+
ASTM E 2336 Grease Duct Enclosure Test Standard – Required by 2006 IMC and NFPA 96	Yes	
UL 1978 Modified for Grease Duct Enclosure System Testing	Yes	
ISO 6944 Fire Resistive Duct Test Standard	Yes	
AC 101 Grease Duct Enclosure Acceptance Criteria first published by ICBO in 1994	Yes	
ASTM E 814 Through Penetration Test Standard	Yes	
ASTM E 119 Test full engulfment of duct, and vertical wall	Yes	
ASTM E136 Combustibility	Yes	
ASTM E 84 Flame Spread and Smoke Development	Yes	Yes
ASTM C 518 Thermal conductivity / durability	Yes	

